

TYPE TEST

The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

Attending the described tasks for the verification of conformity system 3 and the detailed features at harmonised product standard UNE-EN 15102:2008+A1:2012 V2



aitex

textile research institute

Notified Body No. 0161

Nº 14AN0323

Declares at classification report no. 2014AN0323 that the decorative wall covering referenced as:

"ROBINSON RM 903"

have been tested following the mentioned harmonised product standard requirements, being classified according to UNE-EN 13501-1 as:

"C-s1,d0"

Valid for the conformity declaration required at clause ZA.2.2 or the harmonised product standard.

Alcoy, February 11th 2014.



Raquel Muñoz González
CHIEF OF INNOVATION AREA



Jordi Ferré Pascual
HEAD OF FIRE DEPARTMENT

